

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0751-CPR.2-039.2-01**

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Factory made mineral wool (MW) products for thermal insulation of building  
equipment and industrial installations**  
(details cf. annex)

Placed on the market under the name or trade mark of

**DEUTSCHE ROCKWOOL**

Rockwool Straße 37-41  
45966 Gladbeck  
Germany

and produced in the manufacturing plant

**ROCKWOOL, a.s.**

Cihelní 769, Skřečůň  
735 31 Bohumín  
Czech Republik

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 14303:2009+A1:2013**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 29.01.2014 and will remain valid (but no longer than 17.10.2024) as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Gräfelfing, 17.10.2023



Certification Body

*Ralph Alberti*  
Ralph Alberti

A publication of extracts or a referring to the Certificate of Constancy of Performance and its annex requires the prior written approval of FIW München. Certification body accredited by DAkkS according to EN/ISO IEC 17065:2013 according to the certification annex D-ZE-14116-01-00.

Factory: ROCKWOOL, a.s., Cihelni 769, Skřečň, 735 31 Bohumín, Czech Republik

Construction product(s): Factory made mineral wool (MW) products for thermal insulation of building equipment and industrial installations according to EN 14303:2009+A1:2013

Intended use: Thermal insulation products for building equipment and industrial installations

Level(s) or class(es) reaction to fire: for uses subject to regulations on reaction to fire A2L. Products for which a clearly identifiable stage in the production process results in an improvement in the reaction to fire classification by limiting of organic material.

Product			Reaction to fire EN 13501-1				
No.	Form	Name	Description	Classification	Range	Fire Group	Classification report
1	Pipe section	<b>Rockwool 800</b>	Non-combustible mineral wool concentrically wound pipe section covered with a rein-forced aluminium foil Production line: BOH2/CIR3	A2L-s1,d0	Density: 90 kg/m <sup>3</sup> to 110 kg/m <sup>3</sup> Wall thickness: 20 mm to 60 mm Max. organic content: 3,8 mass% and 4,2 kg/m <sup>3</sup>	6	230009473-3
2	Pipe section	<b>Rockwool 800</b>	Non-combustible mineral wool concentrically wound pipe section covered with a rein-forced aluminium foil Production line: BOH2/CIR4	A2L-s1,d0	Density ≤ 100 kg/m <sup>3</sup> Wall thickness ≤ 50 mm Max. organic content: 3,8 mass% and 4,2 kg/m <sup>3</sup>	9	PK-20-197
3	Pipe section	<b>Rockwool 800</b>	Non-combustible mineral wool concentrically wound pipe section covered with a rein-forced aluminium foil Production line: BOH2/CIR5	A2L-s1,d0	Density ≤ 100 kg/m <sup>3</sup> Wall thickness ≤ 50 mm Max. organic content: 3,8 mass% and 4,2 kg/m <sup>3</sup>	12	PK-23-157

Detail information about the insulation products are given in the classification reports

Gräfelting 17.10.2023



Certification Body

*Ralph Alberti*

Ralph Alberti