

Lintel to opening
(By Others)

Annular space filled with
ROCKWOOL RWA45

60x100mm DuctRock collars bonded
to the substrate with FIREPRO Glue

Steel U-profile fixed
20mm from the wall

FIREPRO DuctRock Slab
thickness to suit duct size
Refer to product brochure

100mm Self tapping screws

DuctRock joint at centre of aperture
bonded with FIREPRO Glue

Duct Penetration

Duct support rods
(By Others)

25mm (depth) slits cut into the
DuctRock slab to accommodate
the legs of the u-profile

30mm Maximum allowable
cutout depth for fixings

Typical blockwork plantroom wall - 30 or
60mins as required by buiding design
(By Others)

Please refer to relevant ROCKWOOL product data
sheet for further detail / specification / performance

This CAD Drawing is for illustration purposes only and shall not form part of any contract with ROCKWOOL or hold any contractual force.

Usage of the information remains under the sole responsibility of the purchaser and/or use

ROCKWOOL makes no warranty, representation or guarantee regarding the information contained in the CAD Drawing, the suitability of the products for any particular purposes or the continuing production of any product. To the maximum extent permitted by applicable law, ROCKWOOL disclaims (i) any and all liability arising out of the CAD drawing, the application, use of any product, misuse or inability to use the product (ii) any and all liability, including without limitation special, consequential or incidental damages, and (iii) any and all liability of any nature resulting from the use or reliance upon the information contained in this CAD Drawing. No express or implied warranties are given other than those implied by law.

Information contained in this CAD Drawing is up-to-date as at the date of issue. As ROCKWOOL Limited cannot control or anticipate the conditions under which the information contained in this CAD Drawing may be used, each user should review the information in specific context of the planned use and must obtain approval by Building Control and/or the overseeing body for the project, who are ultimately responsible for approving the correct application/specification.

No license, express or implied, by estoppel or otherwise, to any intellectual property rights is granted by this document or by any conduct of ROCKWOOL.



Pencoed, Bridgend,
South Wales CF35 6NY
t: 01656 868490
technical.solutions@rockwool.co.uk

Title: FIREPRO & HVAC - Plant Room Wall DuctRock Slab System	
Scale: N.T.S.	Date: May 2021
Drawing Reference: RWSD-GEN-5016	Revision 1