

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-0725

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

ROCKWOOL® FIREPRO® Insulated Fire Sleeve; ROCKWOOL® FIREPRO® Insulated Fire Sleeve Plus; ROCKWOOL® FIREPRO® Insulated Fire Duct Sleeve; ROCKWOOL® FIREPRO® Insulated Fire Duct Sleeve Plus

Intended for use as pipe closure devices installed around metal and plastic pipes, including PVC-U circular and rectangular ambient pressure extraction and ventilation “duct” type pipes, to form a penetration seal to reinstate the fire resistance performance of non-load bearing wall and floor constructions, where they have been provided with apertures for the penetration of services

Placed on the Market under the Name of

**Rockwool Ltd
Wern Tarw
Pencoed, Brigend
South Wales, CF35 6NY**

and produced in the manufacturing plant

322/2747 (details held on file by Element)

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in:

ETA 21/0813 issued on 06/09/2021

and

EAD 350454-00-1104

under System 1 for the performance set out in the ETA are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the Constancy of Performance of the Construction Product.

This certificate was first issued on 7 September 2021 and will remain valid as long as neither the ETA, the EAD, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **5 September 2024**

ERO Project Reference: **ERO 034621 P1532**



Certification Manager

CSF406-NL 5.0