

UL-EU CERTIFICATE

Certificate No. UL-EU-01205-CPR
Page 1/6
Date of Issue 2021-09-28

Certificate Holder ROCKWOOL Ltd
Wern Tarw
Pencoed
Bridgend
South Wales
CF35 6NY

Manufacturer A/008

Certified Product Type Fire Stop – Pipe Collar
Product Trade Name Firepro Pipe Collar CE
Trademark N/A
Rating/Classification See Appendix

Harmonised Technical Specifications ETAG 026-2 / EN 13501-2 / EN 13501-1
Expiry date 2031-09-27



A handwritten signature in purple ink, appearing to read 'Chris Miles'.

Authorized Certification Decision Maker
Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01205-CPR
Page 2/6
Date of Issue 2021-09-28

This certificate relates to the use of Firepro Pipe Collar CE for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 5 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes (EI 240).

The product is certificated on the basis of:

- i) Inspection and surveillance of factory production control by UL
- ii) Fire resistance test data in accordance with 1366-3: 2009
- iii) Classification in accordance with EN 13501-2
- iv) Classification in accordance with EN 13501-1
- v) Durability and Servicability as defined in ETAG 026-2

The durability class of Firepro Pipe Collar CE is X - intended for use in conditions exposed to weathering (includes all lower classes).



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01205-CPR
 Page 3/6
 Date of Issue 2021-09-28

Product-type: Pipe Collar		Intended use: Penetration Seal
Basic requirement for construction work	Basic Requirement	Basic requirement for construction work
BWR 1 Mechanical resistance and stability		
-	None	-
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	Class E
EN 13501-2	Resistance to fire	See page 5
BWR 3 Hygiene, health and environment		
EN 1026:2000	Air permeability (material property)	No performance determined
ETAG 026-3, Annex C	Water permeability (material property)	No performance determined
Declaration of manufacturer	Release of dangerous substances	Use category IA1, S/W3 Declaration of manufacturer
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined
EOTA TR 001:2003	Resistance to impact/movement	No performance determined
EOTA TR 001:2003 ISO 11600	Adhesion	No performance determined
BWR 5 Protection against noise		
EN 10140-2/ EN ISO 717-1	Airborne sound insulation	No performance determined
EN 10140-3/ EN ISO 717-2	Impact sound insulation	No performance determined
BWR 6 Energy economy and heat retention		
EN 12664, EN 12667 or EN 12939	Thermal properties	No performance determined
EN ISO 12572 EN 12086	Water vapour permeability	No performance determined
General aspects relating to fitness for use		
ISO 8339: 2005, ISO 9046: 2004 & ISO 7389: 2003	Durability and serviceability	X
BWR 7 Sustainable use of natural resources		
-	-	No performance determined



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01205-CPR
 Page 4/6
 Date of Issue 2021-09-28

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with FirePro Acoustic Intumescent Sealant (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Fire Resistance (mins.)	
							E	EI
Drywall/ Masonry/ Concrete wall	100	10	Both sides	30 x 4	32 mm Firepro Pipe Collar CE	32 mm Ø PVC with 1.8mm wall thickness	120*	120*
					40 mm Firepro Pipe Collar CE	40 mm Ø PVC with 1.8mm wall thickness		
					50 mm Firepro Pipe Collar CE	50 mm Ø PVC with 1.8mm wall thickness		
				30 x 6	55 mm Firepro Pipe Collar CE	55mm Ø PVC with 2.3-3mm wall thickness		
					63 mm Firepro Pipe Collar CE	63mm Ø PVC with 2.3-3mm wall thickness		
				30 x 8	75 mm Firepro Pipe Collar CE	75mm Ø PVC with 3.1-4.8mm wall thickness		
					82 mm Firepro Pipe Collar CE	82mm Ø PVC with 3.1-4.8mm wall thickness		
				30 x 10	90 mm Firepro Pipe Collar CE	90mm Ø PVC with 4.2-7.4mm wall thickness		
					100 mm Firepro Pipe Collar CE	100mm Ø PVC with 4.2-7.4mm wall thickness		
					110 mm Firepro Pipe Collar CE	110mm Ø PVC with 4.2-7.4mm wall thickness		
				40 x 12	125 mm Firepro Pipe Collar CE	125mm Ø PVC with 6.0mm wall thickness		
				40 x 16	140 mm Firepro Pipe Collar CE	140mm Ø PVC with 6.1-7.5mm wall thickness		
				40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PVC with 6.2-9.5mm wall thickness		
				30 x 4	32 mm Firepro Pipe Collar CE	32 mm Ø PP with 2.9mm wall thickness		
					40 mm Firepro Pipe Collar CE	40 mm Ø PP with 2.9mm wall thickness		
					50 mm Firepro Pipe Collar CE	50 mm Ø PP with 2.9mm wall thickness		
				30 x 6	55 mm Firepro Pipe Collar CE	55mm Ø PP with 2.9-4.4mm wall thickness		
					63 mm Firepro Pipe Collar CE	63mm Ø PP with 2.9-4.4mm wall thickness		
				30 x 8	75 mm Firepro Pipe Collar CE	75mm Ø PP with 2.8-6.7mm wall thickness		
					82 mm Firepro Pipe Collar CE	82mm Ø PP with 2.8-6.7mm wall thickness		
				30 x 10	90 mm Firepro Pipe Collar CE	90mm Ø PP with 2.7-10mm wall thickness		
					100 mm Firepro Pipe Collar CE	100mm Ø PP with 2.7-10mm wall thickness		
					110 mm Firepro Pipe Collar CE	110mm Ø PP with 2.7-10mm wall thickness		
				40 x 12	125 mm Firepro Pipe Collar CE	125mm Ø PP with 3.1mm wall thickness		
				40 x 16	140 mm Firepro Pipe Collar CE	140mm Ø PP with 3.5-8.0mm wall thickness		
				40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PP with 4.0-14.5mm wall thickness		
				30 x 4	32 mm Firepro Pipe Collar CE	32 mm Ø PE with 2.9mm wall thickness		
					40 mm Firepro Pipe Collar CE	40 mm Ø PE with 2.9mm wall thickness		
					50 mm Firepro Pipe Collar CE	50 mm Ø PE with 2.9mm wall thickness		
				30 x 6	55 mm Firepro Pipe Collar CE	55mm Ø PE with 2.9-4.4mm wall thickness		
63 mm Firepro Pipe Collar CE	63mm Ø PE with 2.9-4.4mm wall thickness							
30 x 8	75 mm Firepro Pipe Collar CE	75mm Ø PE with 2.8-6.7mm wall thickness						
	82 mm Firepro Pipe Collar CE	82mm Ø PE with 2.8-6.7mm wall thickness						
30 x 10	90 mm Firepro Pipe Collar CE	90mm Ø PE with 2.7-10mm wall thickness						
	100 mm Firepro Pipe Collar CE	100mm Ø PE with 2.7-10mm wall thickness						
	110 mm Firepro Pipe Collar CE	110mm Ø PE with 2.7-10mm wall thickness						
40 x 12	125 mm Firepro Pipe Collar CE	125mm Ø PE with 3.1mm wall thickness						
40 x 16	140 mm Firepro Pipe Collar CE	140mm Ø PE with 3.9-5.8mm wall thickness						
40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PE with 4.9-9.5mm wall thickness						
Masonry/ Concrete wall				30 x 10	110 mm Firepro Pipe Collar CE	110mm Ø PP with 2.7mm wall thickness	120~	120~
				40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PP with 4.0mm wall thickness		
				40 x 24	250 mm Firepro Pipe Collar CE	250mm Ø PP with 6.2mm wall thickness	120*	120*

* Uncapped/Capped (U/C)
 ~Uncapped/Uncapped (U/U)



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01205-CPR
 Page 5/6
 Date of Issue 2021-09-28

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with FirePro Acoustic Intumescent Sealant (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Fire Resistance (mins.)	
							E	EI
Concrete floor	150	10 (to top face of floor)	Soffit	30 x 4	32 mm Firepro Pipe Collar CE	32 mm Ø PVC with 1.8mm wall thickness	240*	240*
					40 mm Firepro Pipe Collar CE	40 mm Ø PVC with 1.8mm wall thickness		
					50 mm Firepro Pipe Collar CE	50 mm Ø PVC with 1.8mm wall thickness		
				30 x 6	55 mm Firepro Pipe Collar CE	55mm Ø PVC with 2.3-3mm wall thickness		
					63 mm Firepro Pipe Collar CE	63mm Ø PVC with 2.3-3mm wall thickness		
				30 x 8	75 mm Firepro Pipe Collar CE	75mm Ø PVC with 3.1-4.8mm wall thickness		
					82 mm Firepro Pipe Collar CE	82mm Ø PVC with 3.1-4.8mm wall thickness		
				30 x 10	90 mm Firepro Pipe Collar CE	90mm Ø PVC with 4.2-7.4mm wall thickness		
					100 mm Firepro Pipe Collar CE	100mm Ø PVC with 4.2-7.4mm wall thickness		
					110 mm Firepro Pipe Collar CE	110mm Ø PVC with 4.2-7.4mm wall thickness		
				40 x 12	125 mm Firepro Pipe Collar CE	125mm Ø PVC with 6.0mm wall thickness		
				40 x 16	140 mm Firepro Pipe Collar CE	140mm Ø PVC with 6.1-7.5mm wall thickness		
				40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PVC with 6.2-9.5mm wall thickness		
				30 x 4	32 mm Firepro Pipe Collar CE	32 mm Ø PP with 2.9mm wall thickness		
					40 mm Firepro Pipe Collar CE	40 mm Ø PP with 2.9mm wall thickness		
					50 mm Firepro Pipe Collar CE	50 mm Ø PP with 2.9mm wall thickness		
				30 x 6	55 mm Firepro Pipe Collar CE	55mm Ø PP with 2.9-4.4mm wall thickness		
					63 mm Firepro Pipe Collar CE	63mm Ø PP with 2.9-4.4mm wall thickness		
				30 x 8	75 mm Firepro Pipe Collar CE	75mm Ø PP with 2.8-6.7mm wall thickness		
					82 mm Firepro Pipe Collar CE	82mm Ø PP with 2.8-6.7mm wall thickness		
				30 x 10	90 mm Firepro Pipe Collar CE	90mm Ø PP with 2.7-10mm wall thickness		
					100 mm Firepro Pipe Collar CE	100mm Ø PP with 2.7-10mm wall thickness		
					110 mm Firepro Pipe Collar CE	110mm Ø PP with 2.7-10mm wall thickness		
				40 x 12	125 mm Firepro Pipe Collar CE	125mm Ø PP with 3.1mm wall thickness		
				40 x 16	140 mm Firepro Pipe Collar CE	140mm Ø PP with 3.5-8.0mm wall thickness		
				40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PP with 4.0-14.6mm wall thickness		
				30 x 4	32 mm Firepro Pipe Collar CE	32 mm Ø PE with 2.9mm wall thickness		
					40 mm Firepro Pipe Collar CE	40 mm Ø PE with 2.9mm wall thickness		
					50 mm Firepro Pipe Collar CE	50 mm Ø PE with 2.9mm wall thickness		
				30 x 6	55 mm Firepro Pipe Collar CE	55mm Ø PE with 2.9-4.4mm wall thickness		
		63 mm Firepro Pipe Collar CE	63mm Ø PE with 2.9-4.4mm wall thickness					
		30 x 8	75 mm Firepro Pipe Collar CE	75mm Ø PE with 2.8-6.7mm wall thickness				
			82 mm Firepro Pipe Collar CE	82mm Ø PE with 2.8-6.7mm wall thickness				
		30 x 10	90 mm Firepro Pipe Collar CE	90mm Ø PE with 2.7-10mm wall thickness				
			100 mm Firepro Pipe Collar CE	100mm Ø PE with 2.7-10mm wall thickness				
			110 mm Firepro Pipe Collar CE	110mm Ø PE with 2.7-10mm wall thickness				
40 x 12	125 mm Firepro Pipe Collar CE	125mm Ø PE with 3.1mm wall thickness						
40 x 16	140 mm Firepro Pipe Collar CE	140mm Ø PE with 3.9-5.8mm wall thickness						
40 x 18	160 mm Firepro Pipe Collar CE	160mm Ø PE with 4.9-9.5mm wall thickness						
10 (to both faces)	Both faces	30 x 10	110 mm Firepro Pipe Collar CE	110mm Ø PP with 2.7mm wall thickness	120~	120~		
		40 x 16	160 mm Firepro Pipe Collar CE	160mm Ø PP with 4.0mm wall thickness	120*	120*		

* Uncapped/Capped (U/C)
 ~Uncapped/Uncapped (U/U)



Appendix UL-EU Certificate

Certification Mark	UL-EU mark
Certificate No.	UL-EU-01205-CPR
Page	6/6
Date of Issue	2021-09-28

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.

