

# UL-EU CERTIFICATE

**Certificate No.** UL-EU-01246-CPR  
**Page** 1/5  
**Date of Issue** 2022-04-25

**Certificate Holder** ROCKWOOL Ltd  
Wern Tarw  
Pencoed  
Bridgend  
South Wales  
CF35 6NY

**Manufacturer** A/008

**Certified Product Type** Fire Stop – Sealant  
**Product Trade Name** ROCKWOOL FirePro Silicone X  
**Trademark** N/A  
**Rating/Classification** See Appendix

**Harmonised Technical Specifications** EAD 350141-00-1106, September 2017 / EN13501-2  
**Expiry date** 2032-04-24



A handwritten signature in purple ink, appearing to be 'Chris Miles', is located in the lower-left quadrant of the page.

---

**Authorized Certification Decision Maker**  
Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01246-CPR  
Page 2/5  
Date of Issue 2022-04-25

This certificate relates to the use of ROCKWOOL FirePro Silicone X for fire stopping where there are joints in or between walls & floors. The detailed scope is given in pages 3 to 5 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes for differing seal configurations and wall/floor constructions

The product is certificated on the basis of:

- i) Inspection and surveillance of factory production control by UL
- ii) Fire resistance test data in accordance with EN 1366-4: 2006
- iii) Classification in accordance with EN 13501-2
- iv) Durability and Servicability as defined in EAD 350141-00-1106

The movement capability of ROCKWOOL FirePro Silicone X joint seals is restricted to 7.5%.

The durability class of ROCKWOOL FirePro Silicone X is Z<sub>1</sub> - intended for use at internal conditions with high humidity, excluding temperatures below 0°C



# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01246-CPR  
 Page 3/5  
 Date of Issue 2022-04-25

Product-type: Sealant		Intended use: Linear Joint & Gap Seal / Penetration Seal	
Assessment method	Essential characteristic	Product Performance	
<b>BWR 2 Safety in case of fire</b>			
EN 13501-1	Reaction to fire	No performance determined	
EN 13501-2	Resistance to fire	See page 5	
<b>BWR 3 Hygiene, health and environment</b>			
Declaration of manufacturer & EN 16516	Content, emission and/or release of dangerous substances	No performance determined	
EN 1026:2000	Air permeability (material property)	No performance determined	
EAD 350141-00-1106, Annex C & EN 12390-8	Water permeability (material property)	No performance determined	
<b>BWR 4 Safety in use</b>			
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined	
EOTA TR 001:2003	Resistance to impact/movement	No performance determined	
EOTA TR 001:2003 ISO 11600 & EAD 350141-00-1106, Clause 2.2.13	Adhesion	No performance determined	
EAD 350141-00-1106, Clause 2.2.12	Durability	Z <sub>1</sub>	
EAD 350141-00-1106, Clause 2.2.13	Movement capacity	No performance determined	
EAD 350141-00-1106, Clause 2.2.14	Cycling of perimeter seals for curtain walls	No performance determined	
EAD 350141-00-1106, Clause 2.2.15	Compression set	No performance determined	
EAD 350141-00-1106, Clause 2.2.16	Linear expansion on setting	No performance determined	
<b>BWR 5 Protection against noise</b>			
EN 10140-1,2,4,5/ EN ISO 717-1	Airborne sound insulation	No performance determined	
<b>BWR 6 Energy economy and heat retention</b>			
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 10456	Thermal properties	No performance determined	
EN ISO 12572, EN 12086, EN ISO 10456	Water vapour permeability	No performance determined	





# Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01246-CPR  
 Page 4/5  
 Date of Issue 2022-04-25

ROCKWOOL FirePro Silicone X – Fire Resistance Classification according to EN 13501-2								
Configuration			Wall to Wall Joint (rigid wall)					
Substrate	Minimum wall Thickness (mm)	Maximum Gap Size (mm)	Seal Position	Minimum Seal Depth (mm)	Backing Material	Minimum Backing Depth (mm)	Fire Resistance (mins.)	
							E	EI
Concrete/ concrete	150	60	Both Sides	5	Stone Mineral Fibre, min. (45kg/m <sup>3</sup> )	50	240	240
Concrete/ steel							240	60
Concrete/ hardwood							180	180
Concrete/ softwood							180	180
Concrete/ concrete				50	25	25	PE backing rod	20
Gypsum Drywall/ Masonry/ Concrete	100	25		20	Stone Mineral Fibre, min. (45kg/m <sup>3</sup> )	60	120	120
Configuration			Floor to Floor/Wall Joint (rigid floor/wall)					
Substrate	Minimum floor Thickness (mm)	Maximum Gap Size (mm)	Seal Position	Minimum Seal Depth (mm)	Backing Material	Minimum Backing Depth (mm)	Fire Resistance (mins.)	
							E	EI
Concrete/ steel	150	60	Unexposed face	5	Stone Mineral Fibre, min. (45kg/m <sup>3</sup> )	50	240	30
Concrete/ steel			Exposed face				240	60
Concrete/ concrete			Unexposed face				240	60
Concrete/ concrete			Exposed face				120	60
Concrete/ concrete		12	Unexposed face	6	PE backing rod	20	240	120
Concrete/ concrete		60		30			240	90



# Appendix UL-EU Certificate

<b>Certification Mark</b>	<b>UL-EU mark</b>
<b>Certificate No.</b>	UL-EU-01246-CPR
<b>Page</b>	5/5
<b>Date of Issue</b>	2022-04-25

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

## PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at [www.ul.com](http://www.ul.com).

Form-ULID-006104 (DCS:27-CP-F0855) 5.0

